

Instructions to Change RD-8 ID961 Display from °F to °C

1. Press and hold "set" button.
2. "PA1" will be displayed, release and press set again to access.
3. "0" will be displayed, press the up arrows to "123".
4. Press "set" to enter.
5. "CP" will be displayed, press the down arrows to "di5"
6. Press "set" to enter
7. "LOC" will be displayed, press down arrow to "dro"
8. Press "set" to enter
9. "1" will be displayed, press down arrow to "0"
10. Press "set" to enter
11. Press "fnc" twice to back out.

°C =0

°F =1